

PUBLIC CODE CHANGE PROPOSAL FORM FOR PUBLIC PROPOSALS IN THE INTERNATIONAL CODES

2009/2010 CODE DEVELOPMENT CYCLE CLOSING DATE: <u>All Proposals Must Be Received by June 1, 2009</u>

The 2009/2010 Code Development Hearings are tentatively scheduled for October 24-November 11, 2009, Baltimore, MD.

Name: Jim Buckley		Date: June 1, 2009
Jurisdiction/Company: Buckley Rumford Co.		
Submitted on Behalf of: Masonry Alliance for Codes and Standards (MACS) & Clay Flue Lining Institute (CFLI)		
Address: 1035 Monroe Street		
City: Port Townsend		State: WA Zip Code: 98368
Phone: 360 385 9974	Ext.	Fax: 360 385 1624
E-mail address: <u>buckley@rumforc</u>	<u>l.com</u>	

Code: <u>R1005.2</u> –09/10

Proponent: Jim Buckley, Buckley Rumford Co., representing the Masonry Alliance for Codes and Standards (MACS) & Clay Flue Lining Institute (CFLI)

Revise as follows:

R1005.2 Decorative shrouds. Decorative shrouds shall not be installed at the termination of factory-built chimneys except where the shrouds are listed and labeled for use with the specific factory built chimney system and installed in accordance with the manufacturer's installation instructions. Decorative shrouds shall comply with the provisions of R1003.9.

Reason: There is no problem adding decorative shrouds to insulated factory-built chimneys listed to UL 103 that are used for masonry fireplaces, stoves, furnaces and many other appliances provided they comply with the general provisions for chimney terminations in Section R1003.9.

Cost Impact: The code change proposal will not increase the cost of construction.

Public Hearing: Committee: AS AM D Assembly: ASF AMF DF